

Certificate of Suitability

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the Certificate number and Regulatory Compliance Mark (RCM) mark on the product of the same type provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the Certificate number and/or RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein.

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Kegu Power Electronics Co.,Ltd		
Address	No 39 East Science & Technology Ave Zone A Science & Technology Industrial Park Nanhai District Foshan Guangdong 528225 China		
Client ID	106857	Global-Mark File Number:	106857-003 System 1 Approval
Certification and Authorized Mark Number	GMA-510325	Revision Number	00
Certification Standard(s)	AS 61347.2.13:2018 & AS/NZS 61347.1:2016 + A1 Lamp Control Gear - Part 2-13: Particular Requirements For D.C Or A.C Supplied Electronic Control Gear For Led Modules.		
Type of Certification	Electrical Safety Product Scheme Global-Mark Electrical Product Safety Certification Scheme		

CERTIFICATE DATES

Certificate Issue Date	9/07/2021
Certificate Last Update Date	
Certification Expiry Date	9/07/2026

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager




Certificate of Suitability

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH015S0300NR19A9	Input: 220-240VAC 50/60Hz,0.11A Output: 33-50VDC, 300mA, Uout:65VDC, 15W ta:45°C tc : 75°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH015S0350NR19A9	Input: 220-240VAC 50/60Hz,0.11A Output: 27-42VDC, 350mA, Uout:55VDC, 14.7W ta:45°C tc : 75°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH018S0300NR19A9	Input: 220-240VAC 50/60Hz,0.11A Output: 45-60VDC, 300mA, Uout:75VDC, 18W ta:45°C tc : 75°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH018S0350NR19A9	Input: 220-240VAC 50/60Hz,0.11A Output: 36-52VDC, 350mA, Uout:65VDC, 18W ta:45°C tc : 75°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH018S0450NR19A9	Input: 220-240VAC 50/60Hz,0.11A Output: 30-40VDC, 450mA, Uout:55VDC, 18W ta:45°C tc : 75°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH018S0600NR19A9	Input: 220-240VAC 50/60Hz,0.11A Output: 19-30VDC, 600mA, Uout:45VDC, 18W ta:45°C tc : 75°C

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager






global-mark®

Certificate of Suitability

Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH018S0700NR19A9	Input: 220-240VAC 50/60Hz,0.11A Output: 17-26VDC, 700mA, Uout:40VDC, 18W ta:45°C tc : 75°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH021S0300NR19A9	Input: 220-240VAC 50/60Hz,0.13A Output: 50-68VDC, 300mA, Uout:85VDC, 20.4W ta:45°C tc : 75°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH021S0350NR19A9	Input: 220-240VAC 50/60Hz,0.13A Output: 45-60VDC, 350mA, Uout:75VDC, 21W ta:45°C tc : 75°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH021S0500NR19A9	Input: 220-240VAC 50/60Hz,0.13A Output: 27-42VDC, 500mA, Uout:55VDC, 21W ta:45°C tc : 75°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH021S0550NR19A9	Input: 220-240VAC 50/60Hz,0.13A Output: 27-38VDC, 550mA, Uout:55VDC, 20.9W ta:45°C tc : 75°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH021S0600NR19A9	Input: 220-240VAC 50/60Hz,0.13A Output: 25-35VDC, 600mA, Uout:50VDC, 21W ta:45°C tc : 75°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH021S0700NR19A9	Input: 220-240VAC 50/60Hz,0.13A Output: 22-30VDC, 700mA, Uout:45VDC, 21W ta:45°C tc : 75°C

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



global-mark®

Certificate of Suitability

Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH024S0300NR22A9	Input: 220-240VAC 50/60Hz,0.15A Output: 60-80VDC, 300mA, Uout:95VDC, 24W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH024S0350NR22A9	Input: 220-240VAC 50/60Hz,0.15A Output: 50-69VDC, 350mA, Uout:85VDC, 24W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH024S0500NR22A9	Input: 220-240VAC 50/60Hz,0.15A Output: 33-47VDC, 500mA, Uout:60VDC, 23.5W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH024S0550NR22A9	Input: 220-240VAC 50/60Hz,0.15A Output: 30-44VDC, 550mA, Uout:60VDC, 24W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH024S0600NR22A9	Input: 220-240VAC 50/60Hz,0.15A Output: 30-40VDC, 600mA, Uout:55VDC, 24W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH024S0700NR22A9	Input: 220-240VAC 50/60Hz,0.15A Output: 25-34VDC, 700mA, Uout:50VDC, 23.8W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH028S0350NR22A9	Input: 220-240VAC 50/60Hz,0.19A Output: 60-80VDC, 350mA, Uout:95VDC, 28W ta:45°C tc : 85°C

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager





global-mark®

Certificate of Suitability

Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH028S0500NR22A9	Input: 220-240VAC 50/60Hz,0.19A Output: 45-56VDC, 500mA, Uout:70VDC, 28W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH028S0550NR22A9	Input: 220-240VAC 50/60Hz,0.19A Output: 32-51VDC, 550mA, Uout:65VDC, 28W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH028S0600NR22A9	Input: 220-240VAC 50/60Hz,0.19A Output: 30-46VDC, 600mA, Uout:60VDC, 27.6W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH028S0700NR22A9	Input: 220-240VAC 50/60Hz,0.19A Output: 30-40VDC, 700mA, Uout:55VDC, 28W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH030S0600NR22A9	Input: 220-240VAC 50/60Hz,0.19A Output: 36-50VDC, 600mA, Uout:65VDC, 30W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH030S0700NR22A9	Input: 220-240VAC 50/60Hz,0.19A Output: 30-44VDC, 700mA, Uout:60VDC, 30.8W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH030S0750NR22A9	Input: 220-240VAC 50/60Hz,0.19A Output: 27-40VDC, 750mA, Uout:55VDC, 30W ta:45°C tc : 85°C

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager





global-mark®

Certificate of Suitability

Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH030S0900NR22A9	Input: 220-240VAC 50/60Hz,0.19A Output: 28-34VDC, 900mA, Uout:50VDC, 30.6W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH036S0700NR22A9	Input: 220-240VAC 50/60Hz,0.22A Output: 36-51VDC, 700mA, Uout:65VDC, 35.7W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH036S0800NR22A9	Input: 220-240VAC 50/60Hz,0.22A Output: 30-45VDC, 800mA, Uout:60VDC, 36W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH036S0850NR22A9	Input: 220-240VAC 50/60Hz,0.22A Output: 30-42VDC, 850mA, Uout:55VDC, 35.7W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH036S0900NR22A9	Input: 220-240VAC 50/60Hz,0.22A Output: 30-40VDC, 900mA, Uout:55VDC, 36W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH042S0700NR22A9	Input: 220-240VAC 50/60Hz,0.28A Output: 45-57VDC, 700mA, Uout:70VDC, 39.9W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH042S0900NR22A9	Input: 220-240VAC 50/60Hz,0.28A Output: 33-46VDC, 900mA, Uout:60VDC, 41.4W ta:45°C tc : 85°C

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



Certificate of Suitability

Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH042S0950NR22A9	Input: 220-240VAC 50/60Hz,0.28A Output: 30-44VDC, 950mA, Uout:60VDC, 41.8W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH042S1000NR22A9	Input: 220-240VAC 50/60Hz,0.28A Output: 30-42VDC, 1000mA, Uout:55VDC, 42W ta:45°C tc : 85°C
Non declared	Power Supply (LED POWER SUPPLY)	KEGU	KEDH042S1050NR22A9	Input: 220-240VAC 50/60Hz,0.28A Output: 30-40VDC, 1050mA, Uout:55VDC, 42W ta:45°C tc : 85°C

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
Classified as NON IC not suitable for residential installation

End of document

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager


